



GOVERNMENT OF TRIPURA
DIRECTORATE OF FIRE & EMERGENCY SERVICES
AGARTALA : TRIPURA

Phone: 0381-232-6451

Email: dg.fire-tr@gov.in

website: www.fireservice.tripura.gov.in

No: FSCRENTFES/2026/00019

Dated: 03/07/2026

Sub: RENEWAL OF FIRE SAFETY CERTIFICATE

With reference to your Application Reference No FSCRENTFES/2026/00019 dated 20/05/2026 Certified that the building or premises as mentioned below have maintained/ fulfilled with the fire prevention and fire safety requirements in accordance with the conditions laid down in the relevant portions of Part-IV of the latest National Building Code and the Tripura Building Rules. The Fire Safety Certificate of the Building / Premises is hereby **Renewed** for a period of 3 (three) year (s) in accordance with renewal from time to time.

Name of the Applicant:-	Lipika Dey (Applicant on Behalf)			
Name of Owner with Plot details:-	S. No.	Owner Name and Address		
	1.	দং ভারতীয় বিদ্যাভবন ব্লক. এফ.এ,সেক্টর, -সল্ট লেক সিটি কোলকাতা-700097 পশ্চিমবঙ্গ		
	S. No.	Plot No	Total Area	Classification
	1.	2574	0.44	----
	2.	2575	2.31	----
	3.	2576	0.34	----
	4.	2577/11714	0.22	----
	5.	2578	1.15	----
6.	2582/9092	0.42	ঢিলা	
Name of the Property/ Organization/ Commercial establishment	Bhavan's Tripura Teacher Training College			
	Total covered area of Building / Premises (in Sqm) : 3013.3			
Address of the Building/ Premises:-	Anandanagar Habitation, West Anandanagar Gram Panchayat, Dukli Block, Post Office Anandanagar B.O - 799004, West Tripura District, Tripura.			

Director,
Fire & Emergency Services,
Or Authorized Signatory
Agartala : Tripura

This certificate will expire on 03/07/2029

Conditions for the Validity of Fire Safety Certificate.

1. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
2. There should not be any change of Trade for which this License has been issued.
3. Building sanctioning authority may verify any deviation with regard to the construction/ occupancy in the building. In case of any deviation, the Fire Safety Certificate stands null and void.
4. Water reservoir should always be kept full up to brim.
5. The entrance and exit and the water reservoir should always be free from any obstruction/ projection.
6. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.

NB:- Based on Recommendation of O/C, MGB Fire Station and DFO(W), Agartala and JD, F&ES, Renewal Fire Safety Certificate (Fire NOC) is issued in favour of “Bhavan's Tripura Teacher Training College, located at Anandanagar Habitation, West Anandanagar Gram Panchayat, Dukli Block, Post Office Anandanagar B.O - 799004, West Tripura District, Tripura.

***** WE SERVE TO SAVE *****